

### **Submittal Sheet**

Section 1 - Specifications Section 2 - Dimensions Section 3 - Electrical

Project Name:	Date:
Location:	
Engineer:	
Contractor:	Rep:

#### 1 SPECIFICATIONS

# **General Specifications**


- ► Product Features
  - Certified to ANSI Z21.13 / CSA 4.9 Gas Boiler Standard
  - ASME "H" stamped, designed and constructed in compliance with the ASME Boiler and Pressure Vessel Code Section IV
  - SA-249 TP316L Stainless Steel Heat Exchanger
  - Maximum System Water Pressure 160 psi [1100 kPa]
  - Field conversion from Natural Gas (factory) to Propane
  - Modulating Burner, 8:1 Turndown, Low Nox emissions <20ppm
  - · Direct Spark Ignition, Sealed Combustion
  - Outdoor Model Std. with Freeze Protection
  - Easy serviceability

- ► Factory Supplied Items
  - 30PSI ASME Pressure Relief Valve
  - ANSI Flange Adapters
- ► Control Features
  - Integrated cascade manager up to 16 units
  - Optimized connectivity options (0-10V, Modbus, etc.)
  - Low Water Flow Safety Control and Indication
- ► Touchscreen Features
  - Performance Graphs for Single and Cascaded units
  - Live status screen for 10+ values (temp, flow rate, etc.)

Water Connections ANSI FLG, in.	ANSI FLG, in. NPT, in. Pipe Diameter, in.			Approx. Weight with Water, lb.				
2 ½	2 (Male)	8	115 / 115	1348				

# **Performance Specifications**

Input Modulation, MBH	Gross Output, MBH	AHRI Net Rating, MBH	Combustion Efficiency, %	Thermal Efficiency, %
236 - 2000	1945	1691	97	98









Version Date: 2024-02-15





### **Submittal Sheet**


Section 1 - Specifications Section 2 - Dimensions Section 3 - Electrical


## **2 DIMENSIONS**

# **Product Dimensions – in.**









# Installation and Service Clearances (Minimum / Recommended) - in.

Тор	Front	Left	Right	Back	Bottom
20/36	20/36	24/36	2/36	20/36	0/0








### **Submittal Sheet**

Section 1 - Specifications Section 2 - Dimensions Section 3 - Electrical

#### 3 ELECTRICAL

#### **Mains Voltage Connections:**

- ► 120VAC / 1 Phase / 60 Hz / 9.7A (Standard)
- ► 208VAC / 3 Phase / 60 Hz / \_\_\_\_A (Amperage dependent on selected system pump)
  - Applicable based on pump selection. Note: Pumps are field supplied.
  - No internal modifications needed.
  - Simply wire 208VAC / 3Phase / 60Hz from the main power supply to the unit and the unit itself is fully ready to transfer that to the pump connections.
- ▶ The boiler circulator (Heating or DHW) can be mounted to relay 1 in the electrical housing. When more circulators are needed (a system circulator, or a DHW circulator with a heating boiler) extra relays must be applied. These are available as an accessory.



#### **Low Voltage Connections:**

29	28	27	26	25	24	23	22	21	20	19	18	17	16	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1
						-	+	-	+	Gnd		Gnd	+	1	+			-	+	В	Α	Gnd						
	fety itch 2	Saf swi		Flue Dam			/CO tern		BUS aging iler	Pui con PV	trol	Pump 0-10 vdc 0-10 V		On/Off thermostat or modulating thermostat		nding			ıs	DHW sensor		System sensor		Outdoor sensor				
	upteur curité 2				et de ninée	Eau b coup à l'ext	pure	AL-f chau gér	dière	Comm de po	mpe	Comm de po 0-10	mpe		0-10		nostat e/ arrêt mostat ulant			JS ère			Cap EC		Cap d syste	е	Capt extér	







Version Date: 2024-02-15